

INDEX

- Above-ground storage tanks, **12.29**
 - atmospheric tank venting, **12.32**
 - corrosion protection, **12.29**
 - delivery system, **12.33**
 - overflow prevention, **12.32**
 - spill containment, **12.32**
 - system monitoring, **12.33**
 - tank connection and access, **12.29**
 - tank fill, **12.31**
 - vapor recovery, **12.33**
- Absolute compressed air pressure, **14.3**
- Absolute filter rating, **3.3**
- Absolute micron filter rating, **3.4**
- Absolute vacuum pressure, **15.2**
- Abstraction, **6.37**
- Acid neutralizers, **3.32**
- Acidification of animal drinking water, **16.5**
- Acid waste and vent system, **10.7**
 - hydrobromic, **10.9**
 - nitric, **10.9**
 - oleum, **10.9**
 - perchloric, **10.9**
 - phosphoric, **10.9**
 - sulfuric, **10.8**
- Activated carbon filters, **3.18**
- Actual cubic feet per minute, **14.4**
- Adapters, **2.47**
- Adiabatic compression, **8.10**
- Adiabatic process, **14.2**
- Adjusted rainfall, **6.46**
- Adsorption, **3.2, 14.20**
- Aeration, **4.20**
- Aftercooler, **14.18**
 - air cooled, **14.18**
 - refrigerant, **14.18**
 - water cooled, **14.18**
- Aggressiveness index, **4.18**
- Air compressor, **14.12**
 - drives, **14.28**
 - duty cycle, **14.40**
 - regulation, **14.29**
 - blow-off, **14.29**
 - continuous method, **14.29**
 - discontinuous method, **14.29**
 - unloading, **14.29**
 - starting unloader, **14.29**
 - types, **14.12**
- Air freezing index, **5.38**
- Air gap, **9.56**
- Air-ground conversion factor, **5.38**
- Air-purifying respirator, **17.20**
- Air rotary well drilling, **6.138**
- Algae, **4.5**
- Alkalinity, **4.6**
- All service insulation jacket, **5.10**
- Allowable compressed air leakage, **14.40**
- Allowable nuclear radiation levels, **10.14**
- Alluvial material, **6.4**
- Alpha radiation, **10.13**
- Aluminum jackets, **5.10**
- American Gas Association, **1.2**
- American National Standards Institute, **1.2**
- American Petroleum Institute, **1.2, 1.3**
- American Society of Heating, Refrigerating and Air Conditioning Engineers, **1.2**
- American Society of Mechanical Engineers, **1.3**
- American Society of Plumbing Engineers, **1.3**
- American Society of Sanitary Engineers, **1.3**
- American Society for Testing and Materials, **1.3**
- American Water Works Association, **1.4**
- American Welding Society, **1.4**

- Animal drinking water:
 - automated central supply, **16.2**
 - bottles, **16.2**
 - disinfection and medication, **16.4**
 - drinking valves, **16.6**
 - equipment sanitizing, **16.18**
 - flushing system, **16.3**
 - monitoring systems, **16.18**
 - pressure-reducing station, **16.5**
 - rack manifold, **16.2**
 - configurations, **16.6**
 - system sizing, **16.8**
 - systems, **16.2**
 - treatment, **16.3**
- Animal facility:
 - equipment washing, **16.18**
 - piping systems, **16.1**
- Animal room:
 - cage flushing water system, **16.13**
 - cleaning and drainage practices, **16.12**
 - drainage system sizing, **16.17**
 - hose stations, **16.12**
 - liquid cleaning agent systems, **16.12**
 - solid waste disposal, **16.15**
 - waste disposal, **16.16**
- Anions, **4.2**
- Aquiclude, **6.4**
- Aquifer, **6.4**
 - classifications, **6.4**
- Artesian aquifer, **6.4**
- As low as reasonably achievable radiation, **10.14**
- AST (*see* Above-ground storage tanks)
- Atmospheres, **15.3**
- Atmospheric pressure, **15.3**
- Atmospheric tank venting, **12.14**
- Atmospheric type vacuum breaker, **9.57**
- Automatic steam heat-up, **11.42**
- Available public sewer, **6.81**
- Average watershed slope, **6.36**
- Axial flow air compressor, **14.16**

- Backflow prevention:
 - high (severe) hazard, **6.119**
 - medium (moderate) hazard, **6.119**
 - nonhazardous (minor) hazard, **6.119**
- Bacteria, **4.5**
- Barometer, **15.3**
- Basket strainers, **3.9**
- Bedding for underground pipe, **6.67**
- Bellows type steam trap, **11.23**
- Berrigan equation, **5.37**

- Beta radiation, **10.13**
- Beta rating, **3.4**
- Bimetallic type steam trap, **11.24**
- Biological fouling, **4.14**
- Biosafety containment (Levels 1–4), **10.22**
- Blackwater, **19.2**
- Blast gates, **15.53**
- Boiler feed pumps, **11.18, 11.31**
- Boiler feedwater, **11.2**
 - conditioning, **4.45**
- Boiler output, **11.7**
- Booster pump system, **9.73**
- Bourdon vacuum gauge, **15.17**
- Breathing air:
 - aftercoolers, **17.26**
 - carbon monoxide converter, **17.27, 17.29**
 - compressor, **17.25**
 - CO monitor, **17.31**
 - coalescing filter/separator, **17.29**
 - component selection and sizing, **17.28**
 - contaminants, **17.23**
 - carbon dioxide, **17.23**
 - carbon monoxide, **17.23**
 - odor, **17.25**
 - solid particles, **17.25**
 - water and water vapor, **17.23**
 - cylinder storage, **17.25**
 - desiccant dryers, **17.29**
 - dew point monitor, **17.32**
 - failure to shift monitor, **17.32**
 - generation, **17.25**
 - high pressure cylinder storage, **17.28**
 - high temperature air monitor, **17.32**
 - humidifiers, **17.27, 17.30**
 - low air pressure monitor, **17.31**
 - moisture separator, **17.27**
 - odor removal, **17.30**
 - oxygen deficiency monitor, **17.31**
 - pipe sizing and materials, **17.31**
 - pressure reducer, **17.28**
 - purification methods, **17.27**
 - purity, **17.23**
 - refrigerated dryers, **17.30**
 - respirator hose, **17.30**
 - respirator manifold, **17.28**
 - selection of purification components, **17.29**
 - system operating range, **17.19**
 - system pressure, **17.31**
 - systems, **17.19**
- Breathing hazard levels, **17.20, 17.21**
- British thermal units, **5.2**

- BTU (*see* British thermal units)
- Building classes, 5.1
- Building house sewer, 9.20
- Building officials code authority, 1.6
- Buoyant tank force, 12.48
- Buried piping design, 6.53
 - in embankment, 6.53
 - negative projection, 6.53
 - positive projection, 6.53
 - restraint for underground pipe:
 - clamps and tie rods, 6.123
 - integral joint restraint, 6.123
 - thrust blocks, 6.124
 - in trench, 6.53
 - in tunnel, 6.53
- Cable tool well drilling, 6.137
- Calcium silicate insulation, 5.8
- Cantilever pumps, 9.17
- Capacitance vacuum gauge, 15.17
- Cartridge filter, 3.19
 - housings, 3.20
 - media, 3.20
 - acrylic copolymer, 3.20
 - depth filters, 3.19
 - glass, 3.20
 - nylon, 3.20
 - polypropylene, 3.20
 - polysulfone, 3.20
 - PTFE, 3.20
 - filter seals, 3.21
- Catch basins, 6.11
- Cations, 4.3
- Cellular glass insulation, 5.7
- Centistrokes, 12.2
- Centrifugal air compressors, 14.16
- Centrifugal vacuum pump, 15.12
- Chlorides, 4.6
- Chlorination of animal drinking water, 16.5
- Circuit and loop vents, 9.38
- Clarification, 4.21
- Clay, 7.2
- Clean steam, 11.12
- Cleanouts, 9.7
- Coaxial liquid fuel fill hose, 12.14
- Code of federal regulations, 1.5
- Cold Region Research and Engineering Laboratory (CRREL), U.S. Army, 5.36
- Colloids, 4.3
- Colony forming units, 4.5
- Color, 4.5
- Combination type grate, 6.15
- Combination vacuum cleaning system, 15.49
- Combustible liquid, 12.2
- Compound type water meter, 9.55
- Compressed air:
 - activated carbon filters, 14.20
 - after-filters, 14.20
 - automatic bucket traps, 14.23
 - automatic electronic trap, 14.23
 - automatic float traps, 14.23
 - coalescing filter, 14.20
 - combination filters, 14.20
 - drain traps, 14.23
 - dryer selection, 14.27
 - dryers, 14.23
 - absorption, 14.24
 - adsorption, 14.26
 - high pressure, 14.23
 - refrigerant, 14.24
 - elevation correction factor, 14.4
 - filter selection, 14.22
 - filters, 14.19
 - flow rate measurement, 14.4
 - for health care facilities, 14.100
 - hose and fittings, 14.32
 - impurities, 14.8
 - gas, 14.11
 - liquids, 14.11
 - particulates, 14.11
 - vapor, 14.11
 - inlet filters, 14.19
 - instrumentation, 14.60
 - intake air filters, 14.20
 - lubricators, 14.28
 - mechanical separation, 14.20
 - oil removal filters, 14.20
 - pipng system design, 14.41
 - point of use filters, 14.20
 - prefilters, 14.19
 - pressure measurement, 14.2
 - receivers, 14.30
 - separators, 14.22
 - active, 14.22
 - passive, 14.22
 - silencers, 14.17
 - temperature correction factor, 14.4
 - use factor, 14.40
- Compressed gas, 14.2
 - corrosive, 14.65
 - cryogenic, 14.65
 - cylinder storage, 14.68
 - flammable, 14.65

- Compressed gas (*Cont.*):
 - flow meters, **14.79**
 - for health care facilities, **14.98**
 - inert gases, **14.65**
 - low-temperature cutoff, **14.79**
 - oxidizers, **14.65**
 - pyrophoric, **14.65**
 - toxic and poisonous, **14.65**
- Compressed gas association, **1.4**
- Condensate:
 - collection leg, **11.34**
 - cooler, **11.34**
 - drain lines, **11.34**
 - drainage problems, **11.51**
 - main pipe sizing, **11.45**
 - recovery system, **11.33**
 - system component selection and sizing, **11.36**
 - system corrosion, **11.52**
 - transfer pumps, **11.35**
- Condensation prevention by insulation, **5.14**
- Conductance, **5.3**
- Conduction, **5.3**
- Conductivity, **5.3**
- Confined aquifer, **6.4**
- Consolidated rocks, **6.3**
- Constant flow breathing air system, **17.20**
- Containment sump, **12.11, 12.12**
- Continuous deionization, **4.33**
- Convection, **5.3**
- Conventional large roof storm water drainage, **9.45**
- Conventional small roof storm water drainage, **9.44**
- Cooling water conditioning, **4.46**
- Cooling water for air compressors, **14.31**
- Corrosion, **4.15**
- Corrosion protection for USTs, **12.8**
- Cosmic radiation, **10.14**
- Counterflow condensate return, **11.10**
- Crevice attack corrosion, **4.15**
- Critical inlet, **6.31**
- Crown vented traps, **9.9**
- Cryogenic dewers, **8.3**
- Cryogenic gas, **8.1**
 - normal evaporation rate, **8.3**
- Cryogenic pipe materials and insulation, **8.11**
- Cryogenic piping, **8.12**
- Cryogenic pressure relief valves, **8.10**
- Cryogenic storage tank, **8.2**
- Cryogenic tank pad, **8.7**
- Curb type grate, **6.15**
- Curb valve, **6.117**
- Current good manufacturing practice, **1.4**
- Cylinder bank, **14.72**
- Cylinder manifold, **14.73**
 - differential, **14.72**
 - fully automatic, **14.72**
 - manual, **14.72**
 - materials, **14.71**
 - semiautomatic, **14.72**
- Deaeration, **4.20**
- Dealkalizing, **4.22**
- Decarbonation, **4.20, 4.22**
- Deep bed sand filters, **3.14**
- Deformation of pipe at structures, **6.69**
- Degrees Celsius, **5.2**
- Degrees Fahrenheit, **5.2**
- Degrees Kelvin, **5.2**
- Degrees Rankine, **5.2**
- Deliquescent compressed air dryer, **14.35**
- Demand flow breathing air system, **17.20**
- Dendritic ice, **5.24**
- Dental air compressor assembly, **14.133**
- Dental compressed air, **14.133**
 - pressure and flow rate, **14.133**
- Dental vacuum system, **15.36**
 - diversity factor, **15.38**
 - exhaust, **15.41**
 - flow rates, **15.38**
 - pipe material, **15.42**
 - pressure, **15.37**
 - pumps, **15.36**
 - separators, **15.37**
 - sizing, **15.43**
- Depression storage, **6.37**
- Depth filter, **3.3**
- Depth of freeze in soils, **5.36**
- Desiccant compressed air dryer, **14.39**
- Desiccant dryers, **14.26**
 - heat activated, **14.26**
 - pressure swing, **14.26**
- Design storm, **6.21**
- Dew point of compressed air, **14.7**
- Diaphragm air compressors, **14.14**
- Diaphragm type vacuum pump, **15.12**
- Diaphragm vacuum gauge, **15.17**
- Diatomaceous earth filters, **3.17**
- Direct fill port, **12.13**
- Direct operated PRV, **9.65**

- Direct steam injection, **11.28**
- Disk type water meter, **9.55**
- Dispenser pan, **12.28**
- Displacement type air compressors, **14.12**
- Display fountain:
 - fill and drain, **18.1**
 - filters, **18.3**
 - flow through, **18.1**
 - lights, **18.2**
 - pool recirculation system, **18.2**
 - recirculation type, **18.2**
- Display pool:
 - heater, **18.5**
 - overflows, **18.5**
 - vacuum cleaning, **18.4**
 - water makeup, **18.4**
 - water treatment, **18.5**
- Dissolved gases, **4.7**
- Dissolved iron, **4.6**
- Dissolved magnesium, **4.6**
- Dissolved minerals, **4.6**
- Dissolved organics, **4.6**
- Dissolved silica, **4.7**
- Dissolved trace elements, **4.7**
- Distillation, **4.23**
 - multieffect, **4.24**
 - single-stage, **4.23**
 - vapor compression, **4.23**
- Domestic water supply, **6.143**
- Double check valve backflow preventer, **9.57**
- Double-wall shell and tube heat exchangers, **9.89**
- Downfeed water supply systems, **9.60**
- Drainage:
 - fixture units, **9.3**
 - inlets, **6.12**
 - structures, **6.11**
 - system pitch, **9.11**
- Drinking water systems, **20.1**
 - chiller, **20.2**
 - fixtures, **20.1**
 - installation, **20.3**
 - pipe and insulation sizing, **20.5**
 - system design, **20.4**
- Drop manhole, **6.16**
- Drop tube, **12.13**
- Drum traps, **9.9**
- Dry air, **14.4**
- Dry disconnect coupling, **12.14**
- Dry interstitial monitoring, **12.20**
- Dry steam, **11.2**
- Dry vacuum cleaning system, **15.49**
- Dual air compressor regulation, **14.29**
- Dynamic air compressors, **14.12**
- Earth load, **6.54**
- Effective filtration area, **3.21**
- Elastomeric plastic insulation, **5.8**
- Electric heat tracing, **5.50**
- Electrolytes, **4.3**
- Electronic tank gauging:
 - magnetostrictive, **12.19**
 - ultrasonic, **12.19**
- Electropolishing decontamination, **10.19**
- Elevated water tank, **9.68**
 - water supply system, **9.62**
- Emergency drench combination equipment, **17.8**
- Emergency drench equipment, **17.2**
 - alarms, **17.16**
 - controls, **17.12**
 - dimensional requirements, **17.9**
 - extreme temperature protection, **17.12**
 - flow control, **17.16**
 - flushing water disposal, **17.16**
 - installation requirements, **17.9**
 - location, **17.10**
 - pipe sizing and material, **17.18**
 - plumbed systems, **17.2**
 - self-contained, **17.2**
 - stations, **17.11**
 - system selection, **17.17**
 - visibility, **17.17**
 - water supply pressure and flow rates, **17.17**
 - water temperature, **17.11**
- Emergency drench hoses, **17.6**
- Emergency eyewash, **17.3**
- Emergency facewash, **17.5**
- Emergency generator fuel storage, **12.38**
- Emergency showers, **17.3**
- Endotoxins, **4.5**
- Enthalpy, **11.3**
- Environmental Protection Agency, **1.5**
- Equipment decontamination, **10.19**
- Equivalent direct radiation, **11.6**
- Equivalent insulation thickness, **5.21**
- Equivalent length of piping, **9.3**
- Equivalent weight, **4.3**
- Erosion corrosion of piping, **4.15**
- Evaporation of water from soil, **7.3**

- Evapotranspiration, 7.3
- Excessive water pressure adjustment, 9.64
- Exfiltration, 6.34
- Expansion loops, 2.91
- Expansion tanks, 9.89

- Factions, 7.2
- Fall-off, 9.68
- Feedwater, 3.2, 4.3
- Fiberglass insulation, 5.7
- Field supporting strength, 6.67
- Fill hose connection, 12.14
- Fill port assembly, 12.14
- Filter, 3.14
 - classifications, 3.14
 - differential pressure, 3.19
 - efficiency, 3.4
 - extractables, 3.3
 - mechanical capture, 3.2
 - ratings, 3.3
- Filtration, 3.2
 - activated carbon, 4.27
 - deep bed sand, 4.27
- Fire hydrants, 6.126
- Fire protection monitors, 6.128
- Fire pump fuel storage, 12.37
- Fire suppression water drainage, 10.27
- Firesafe valves, 2.61
- Fittings, 2.30
 - acid resistant, 2.32
 - bronze, 2.31
 - cast copper alloy, 2.31
 - cast iron, 2.30
 - dielectric, 2.32
 - glass, 2.32
 - malleable iron, 2.31
 - plastic, 2.32
 - stainless steel, 2.32
 - wrought copper and copper alloy, 2.32
- Fixture units, 9.4
- Fixture mounting height, 9.100
- Flammable liquid, 12.2
- Flash point, 12.2
- Flash steam from higher pressure process, 11.14
- Flash tanks, 11.35
- Flexible pipe:
 - longitudinal deformation, 6.69
 - radial deflection, 6.69
- Flexible piping, 6.67
- Float and lever steam trap, 11.21
- Float and thermostatic steam trap, 11.21

- Floor drains, 9.7
- Flotation, 6.105, 12.48
- Fluoroplastics, 2.26
- Foamed plastic insulation, 5.8
- Food and Drug Administration, 1.5
- Force main pipe material, 6.103
- Formazin turbidity unit, 4.12
- Free air, 14.4
 - delivered, 14.4
- Freeze protection safety factors, 5.56
- Freezing of sewer and water lines, 5.30
- Freezing of water, 5.24
 - in atmospheric vessels, 5.27
- Frost closure of vents, 5.35
- Frost depth calculation, 5.36
- Fuel gas, physical properties, 13.2
- Fuel gas system, 13.1
 - operating pressures, 13.3
- Full facepiece respirators, 17.22
- Full pressure suits, 17.23
- Fully instantaneous type water heaters, 9.76
- Fungi, 4.5
- Fusion parameter, 5.38

- Galvanic corrosion, 4.15
- Gamma radiation, 10.13
- Gas booster pump:
 - heat exchangers, 13.49
 - system safety devices, 13.50
- Gas transfer vacuum pumps, 15.12
- Gas warmers, 14.79
- Gauge pressure, 14.3
- General pipe corrosion, 4.15
- Granular filters, 3.15
- Granular sand filter media, 3.14
- Grates for storm water:
 - combination grate, 6.15
 - curb grate, 6.15
 - plain grate, 6.15
- Gratings, 6.12
- Gravel packing, 6.136
- Gravimetric measurement, 4.9
- Gravity drainage pipe sizing, 9.11
- Gravity drainage system design, 9.11
- Gravity drop, 12.11
- Gravity flow condensate return system, 11.11
- Gravity sand filter, 3.15
- Gray water:
 - design flow, 19.3
 - system, 19.2
 - treatment systems, 19.4

- Grease interceptor, **3.24**
- Groundwater, **6.2**
 - monitoring, **12.22**
 - wells, **6.131**
- Hair interceptor, **3.32**
- Half-facepiece respirators, **17.21**
- Hangers and supports, **2.81**
- Hardness zones, **7.6**
- Hardness of water, **4.7**
- Heat, **5.2, 11.3**
- Heat exchangers, **21.1**
 - air cooled type, **21.14**
 - choosing off the shelf heat exchangers, **21.9**
 - codes, **21.1**
 - copper tube properties, **21.18**
 - design, **21.17**
 - fouling factor, **21.17**
 - heat exchanger, **21.00**
 - heat transfer coefficients, **21.17**
 - immersion type, **21.14**
 - plate type, **21.10**
 - plate and frame type, **21.10**
 - pressure & temperature, **21.00**
 - prime surface, **21.13**
 - relief valve, **21.19**
 - selection, **21.15**
 - shell and tube, **21.3**
 - straight tube, **21.5**
- Heat flow, **5.4**
- Heat flux, **5.4**
- Heat loss from elevated tanks, **5.28**
- Heat tracing, **5.50**
 - for indoor tanks, **5.55**
 - steam:
 - pipe materials, **5.57**
 - pipe size, **5.57**
 - system pressure, **5.60**
 - temperature control, **5.65**
- Heat transfer, **5.3**
 - through steel tank walls, **13.40**
- Heat up methods for steam, **11.42**
- High-pressure condensate system, **11.49**
- High-pressure cylinder:
 - ultraclean, **14.68**
- High-pressure gas cylinders:
 - aluminum, **14.68**
 - carbon steel, **14.68**
 - categories, **14.68**
 - stainless steel, **14.68**
- High-pressure steam, **11.8**
- High nuclear radiation area, **10.14**
- Hood and helmet respirators, **17.22**
- Hot water temperature, **9.78**
 - maintenance, **9.90**
- Hunter curve, **9.3**
- Hybrid system, **9.68, 9.75**
- Hydraulic length modified, **6.46**
- Hydraulic rotary well drilling, **6.138**
- Hydrocarbon fuel gas compounds, **13.1**
- Hydrologic soil groups, **6.70**
- Hydrological cycle, **6.2**
- Hydrophilic filter, **3.3**
- Hydrophobic filter, **3.3**
- Hydropneumatic tank system, **9.74**
- Hydrostatic tank monitoring, **12.20**
- Immiscible liquids, **4.3**
- Imperviousness factor, **6.22, 9.49**
- Impurity measurement for water, **4.9**
- In-ground vapor monitoring for USTs, **12.22**
- Inches of mercury pressure measurement, **15.2**
- Industrial specialty gases, **14.135**
- Industrial liquid waste systems, **10.25**
- Infectious waste drainage systems, **10.19, 10.21**
- Infectious waste system vents, **10.21**
- Infiltration, **6.35, 6.85**
- Inlet cubic feet per minute, **14.4**
- Inlet filters, **14.20**
- Inlet time, **6.29**
- Installation comparison, AST or UST, **12.46**
- Instrument and control compressed air, **14.60**
- Insulating cement, **5.9**
- Insulation:
 - adhesives, **5.13**
 - coatings, **5.13**
 - fire ratings:
 - flame spread, **5.5**
 - smoke developed, **5.5**
 - tunnel test, **5.5**
 - jackets, **5.9**
 - sealant, **5.13**
 - selection, **5.14**
- Intake compressed air filters:
 - felt filters, **14.21**
 - oil bath filters, **14.21**
 - oil wetted labyrinth filters, **14.21**
 - paper filters, **14.21**
- Interceptor, **3.2, 3.23**
 - drainage, **6.7**

- Intergranular piping corrosion, **4.15**
- Interstitial tank monitoring, **12.20**
- Inverted bucket steam trap, **11.23**
- Ion exchange resins, **4.27**
- Ions, **4.3**
- ISO 9000, **1.5**
- Isobaric compression process, **14.2**
- Isochoric compression process, **14.2**
- Isothermal compression process, **14.2**

- Jackson turbidity unit, **4.12**
- Jet type display fountain nozzles, **18.2**
- Joints, **2.34**
 - brazed, **2.36**
 - burned, **2.40**
 - caulked, **2.34**
 - compression couplings, **2.35**
 - compression gasket, **2.37**
 - flanged, **2.43**
 - flared, **2.37**
 - for FRP piping, **2.49**
 - grooved, **2.39**
 - heat fusion, **2.48**
 - hinged clamp, **2.44**
 - mechanical joint, **2.39**
 - for plastic piping, **2.47**
 - screwed, **2.35**
 - soldered, **2.36**
 - solvent welding, **2.48**
 - welded, **2.40**
 - wiped, **2.39**

- k* factor, **5.3**
- Kill tank for infectious wastes, **10.23**
- Kilocalorie, **5.2**
- Kinematic viscosity, **12.2**
- Knock-out pot vacuum filter, **15.18**

- Laboratory drainage and vent systems, **10.7**
- Laboratory vacuum pump sizing, **15.48**
- Laboratory vacuum systems, **15.44**
 - allowable friction loss, **15.48**
 - diversity factor, **15.47**
 - flow rate, **15.47**
 - inlets, **15.47**
 - pipe material and joints, **15.45**
 - pipe sizing, **15.48**
 - pumps, **15.44**
- Laboratory waste treatment, **10.10**
- Labyrinth steam trap, **11.26**
- Lagging, **5.11**

- Land use, **6.36**
- Langelier saturation index, **4.16**
- Latent heat of vaporization, **11.3**
 - of propane, **13.41**
- Lawn sprinkler:
 - bubbler and drip heads, **7.5**
 - rotating heads, **7.5**
 - spray heads, **7.4**
- Leakage from ASTs, **12.32**
- Leakage from AST piping, **12.22**
- Leakage from USTs, **12.17**
- Leakage into sumps, **12.23**
- Level measurement, **22.23**
 - bubblers, **22.27**
 - capacitance, **22.23**
 - displacement, **22.30**
 - float based, **22.23**
 - magnetostrictive, **22.32**
 - nuclear, **22.29**
 - pressure gauge, **22.27**
 - radar, **22.29**
 - radio frequency, **22.23**
 - selection, **22.33**
 - ultrasonic, **22.28**
- Limited discharge roof drainage systems, **9.49**
- Limulus amoebocyte lysate water test, **4.5**
- Liquefied petroleum gas, **13.28**
 - excess flow valve, **13.35**
 - filler valves, **13.36**
 - gas pipe sizing, **13.42**
 - liquid level gauges, **13.36**
 - mixers, **13.37**
 - pressure relief devices, **13.33**
 - pumps, **13.43**
 - regulators, **13.33**
 - service line valves, **13.35**
 - system design, **13.39**
 - vapor equalizing valves, **13.36**
 - vapor pressure, **13.33**
 - vaporizer, **13.37**
- Liquid expansion steam trap, **11.25**
- Liquid fuel, **12.2**
 - definitions, **12.1**
 - flow rate, **12.41**
 - piping materials, **12.40**
 - pressure dispensing system, **12.26**
 - product dispenser, **12.26**
 - product dispensing systems, **12.25**
 - simultaneous use factor, **12.41**
 - submersible pump sizing, **12.42**

- vacuum dispensing system, **12.26**
 - vacuum pump sizing, **12.43**
 - Liquid fuel pipe sizing, **12.41**
 - Liquid monitoring, **12.20**
 - Liquid petroleum, **12.2**
 - Liquid ring:
 - air compressors, **14.12**
 - vacuum pump, **15.12**
 - medical/surgical, **15.20**
 - Liquid infectious waste decontamination system, **10.23**
 - Lithosphere, **6.3**
 - Live loads for underground piping, **6.57**
 - Load factor for underground piping, **6.57**
 - Local barometric pressure, **14.3, 15.3**
 - Localized pipe corrosion, **4.15**
 - Loose float steam trap, **11.20**
 - Low-pressure steam, **11.8**
 - LPG (*see* Liquefied petroleum gas)

 - McLeod vacuum gauge, **15.16**
 - Main steam pressure regulating valves, **11.15**
 - Manhole, **6.12**
 - construction, **6.78**
 - frame and cover, **6.82**
 - grating, **6.12**
 - repair, **6.83**
 - spacing, **6.97**
 - steps, **6.83**
 - Manifold and regulator pure gas purge devices, **14.78**
 - Manometer vacuum gauge, **15.16**
 - Manufacturers' standardization of valve and fittings industry, **1.7**
 - Manway tank risers, **12.11**
 - Measurement methods, **22.1**
 - Reynolds number, **22.2**
 - Newtonian fluids, **22.3**
 - sensors, **22.3**
 - hydraulic radius, **22.3**
 - flowmeter classification, **22.4**
 - flowmeters:
 - variable area, **22.5**
 - thermal mass, **22.5**
 - coriolis effect, **22.8**
 - oriface, **22.8**
 - venturi tube, **22.10**
 - flow tube, **22.11**
 - pitot tube meter, **22.11**
 - elbow tap, **22.13**
 - flow nozzle, **22.13**
 - rotary vane, **22.14**
 - helix, **22.14**
 - disk meter, **22.14**
 - turbine meter, **22.15**
 - vortex 1, **22.15**
 - swirl, **22.15**
 - target, **22.17**
 - oval gear, **22.17**
 - electronic flowmeter, **22.18**
 - magnetic, **22.18**
 - ultrasonic, **22.19**
 - transit time, **22.20**
 - selection, **22.21**
- Mechanical steam traps, **11.20**
- Medical compressed air supply, **14.106**
- Medical/surgical vacuum:
 - alarms, **15.23**
 - flow rate, **15.25**
 - fluid filter traps, **15.22**
 - inlets, **15.23**
 - interconnecting piping, **15.23**
 - pipe material, **15.24**
 - pipe sizing, **15.26**
 - pump exhaust, **15.23**
 - pump sizing, **15.26**
 - pumps, **15.20**
 - receiver drains, **15.22**
 - receivers, **15.22**
 - separators, **15.22**
 - system alarms, **15.31**
 - system diversity factor, **15.25**
 - system tests, **15.31**
 - systems, **15.19**
 - valves and valve locations, **15.31**
- Medication of animal drinking water, **16.5**
- Medium pressure steam, **11.8**
- Megohms water purity measurement, **4.11**
- Membrane filter test:
 - air permeability test, **3.5**
 - bubble point test, **3.5**
 - diffusion test, **3.6**
 - water breakthrough test, **3.6**
 - water intrusion test, **3.6**
 - water pressure integrity test, **3.6**
- Membrane filtration, **4.36**
- Membrane selection, **4.38**
- Mesh, **3.9**
- Metallic alloy designations, **2.78**
- Metric pipe sizes, **2.80**

- Microbial control for water, **4.40**
 - chemicals, **4.40**
 - filtering, **4.40**
 - heat, **4.42**
 - ozone, **4.42**
 - ultraviolet radiation, **4.41**
- Micrometer, **3.3**
- Micromhos water purity measurement, **4.11**
- Micron, **3.3**
 - rating, **3.3**
 - vacuum, **15.3**
- Microorganisms, **4.5**
 - measurement, **4.5**
- Millibar, **15.5**
- Mineral fiber insulation, **5.9**
- Minimum allowable water pressure, **9.69**
- Minimum velocity of sanitary drainage, **9.11**
- Mixed flow air compressors, **14.17**
- Model regional building codes, **1.6**
- Moisture content of compressed air, **14.5**
- Molecular sieve, **14.75**
- Molecular weight, **3.3**
- Mouthpiece respirators, **17.21**
- Multieffect distillation, **4.24**
- Mushroom type display fountain nozzles, **18.2**

- Nanofiltration for water, **4.40**
- National Electrical Manufacturers Association, **1.7**
- National Fire Protection Association, **1.7**
- National Institutes of Health, **1.7**
- National Oceanic and Atmospheric Administration, **1.7**
- National Sanitation Foundation, International, **1.8**
- Natural gas, **13.1**
 - allowable friction loss, **13.18**
 - appliance regulator, **13.8**
 - atmospheric regulator, **13.8**
 - backpressure regulator, **13.8**
 - intermediate regulator, **13.8**
 - line regulator, **13.8**
 - maximum probable demand, **13.19**
 - meters, **13.7**
 - pipe materials, **13.25**
 - pipe sizing, **13.19**
 - pressure, **14.2**
 - pressure booster system, **13.48**
 - regulators, **13.7**
 - regulator selection, **13.9**
 - types of service, **13.5**
- Negative gauge pressure, **15.2**
- Nephelometric turbidity unit, **4.12**
- Nitrogen:
 - for health care facilities, **14.124**
 - storage for health care facilities, **14.73**
- Nitrous oxide:
 - bulk storage, **14.104**
 - for health care facilities, **14.99**
- Noise reduction by insulation, **5.19**
- Nominal filter:
 - pore rating, **3.4**
 - rating, **3.4**
- Nonpotable water systems, **19.1**
- Nuclear radiation, **10.12**
- Nuclear Regulatory Commission, **1.7**
- Nucleation, **5.25**

- Occupational Safety and Health Administration, **1.6**
- Oil separator, **3.29**, **14.22**
- One-pipe steam system, **11.10**
- Open type bucket steam trap, **11.21**
- Overflows, **9.70**
- Overland flow time, **6.30**
- Oxygen:
 - bulk storage, **14.100**
 - for health care facilities, **14.100**

- Parallel flow condensate return, **11.10**
- Parallel steam trapping, **11.52**
- Passivation, **2.11**
- Pathogenic organisms, **4.5**
- Perched aquifer, **6.4**
- Perched water, **6.2**
- Percolation, **7.3**
- Perm, **5.5**
- Permeance, **5.5**
- Personnel protection by insulation, **5.16**
- Personnel decontamination, **10.19**
- pH, **4.9**
- pH measurement, **22.41**
- Phase 1 and 2 (*see* Vapor recovery)
- Piled material space, **22.60**
- Pilot-operated PRV, **9.66**
- Pipe:
 - acid-resistant cast iron pipe, **2.7**
 - acrylonitrile butadiene styrene, **2.25**
 - aluminum, **2.6**
 - asbestos cement, **2.28**
 - brass, **2.6**
 - carbon steel, **2.7**
 - cast iron soil, **2.7**

- chlorinated polyvinyl chloride, 2.24
- concrete, 2.28
- copper tubing, 2.8
- double-wall piping, 2.48
- ductile iron, 2.9
- expansion, 2.91
- glass, 2.28
- lead, 2.9
- polybutylene, 2.26
- polyethylene, 2.25
- polypropylene, 2.25
- polyvinyl chloride, 2.24
- stainless steel, 2.10
- vitrified clay, 2.28
- Piston steam trap, 11.25
- Piston type air compressors, 14.12
- Pitting, 4.15
- Plastic jackets, 5.13
- Plastic pipe, 2.24
- Plastic pipe standards and nomenclature, 2.17
- Platinum cobalt unit, 4.12
- Pleated filter, 3.19
- Plumbing codes, 9.2
- Plumbing fixtures, 9.3
- Point-of-use water heaters, 9.93
- Polytropic process, 14.2
- Pores, 7.2
- Potable water:
 - contamination prevention, 9.56
 - probable demand, 9.62
 - supply, 6.112
 - system, 9.55
 - velocity, 9.59
- Potassium, 4.7
- Potential evapotranspiration, 7.6
- Precious metals interceptor, 3.31
- Precoat (septum) filters, 3.17
- Preformed filters, 3.14
- Pressure demand breathing air system, 17.20
- Pressure monitoring, 12.21
- Pressure regulating valve, 9.65
- Pressure sand filter, 3.14
- Pressure type vacuum breaker, 9.57
- Pressure and vacuum measurement, 22.38
 - bourdon gauge, 15.17, 22.38
 - capacitance meter, 22.39
 - diaphragm gauge, 22.39
 - manometer, 15.16, 22.38
 - McLeod gauge, 15.16
 - strain gauge, 15.17, 22.39
- Private sewage disposal, 9.21
- Propane:
 - equipment locations, 13.31
 - mixers, 13.37
 - storage tanks, 13.28
 - tank foundations, 13.31
- Pure steam, 11.12
- Pure water:
 - generation, 4.55
 - for laboratories, 4.51
 - standards:
 - American Society for Testing and Materials, 4.52
 - Association for the Advancement of Medical Instrumentation, 4.52
 - College of American Pathologists, 4.52
 - electronics grade water, 4.53
 - National Committee for Clinical Laboratory Standards, 4.52
- Pyrogens, 4.5
- Quantities of sewage flow, 6.25
- Rad, 10.9
- Radiant heat, 5.4
- Radiation dose, 10.15
- Radiation equivalent to man, 10.14
- Radiation measurement, 10.13
- Radiation safety officer, 10.17
- Radiation shielding, 10.15
- Radioactive decontamination, 10.19
- Radioactive drainage pipe selection, 10.17
- Radioactive material, 10.16
 - approval for use, 10.16
- Radioactive waste drainage and vent system, 10.12
- Radioactivity, 10.12
- Rainfall intensity, 6.22
- Rainstorm duration, 6.28
- Rate of rainfall, 6.22, 9.48
- Rational formula for storm water drainage, 6.21, 9.48
- Raw water, 3.2
- Reciprocating air compressor, 14.13
- Reciprocating vacuum pump, 15.12
- Recycled water system, 19.2
- Reduced pressure zone backflow preventer, 9.57
- Reduction of heat loss by insulation, 5.14
- Refrigerated compressed air dryers, 14.24
- Regenerable ion exchange, 4.29
- Regional building codes, 9.2

- Regulated substance, **12.1**
- Regulator:
 - double stage, **14.72**
 - high pressure, **14.72**
 - single stage, **14.72**
- Reinforced thermosetting resin pipe, **2.27**
- Relative humidity, **14.7**
- Relief vents, **9.38**
- Remote fill port, **12.13**
- Residual water supply, **6.146**
- Respirator hose, **17.28**
- Return period, **6.28**
- Reverse flange type manway for UST, **12.11**
- Reverse osmosis, **4.36**
 - hollow fiber, **4.37**
 - plate and frame, **4.37**
 - spiral wound, **4.37**
 - tubular, **4.37**
- Rigid pipe, **6.53**
- Roentgen, **10.14**
- Roof drainage systems, **9.44**
- Roof drains, **9.43**
- Roof storm water retention, **6.35**
- Rotary air compressor, **14.16**
- Rotary lobe vacuum pump, **15.15**
- Rotary screw air compressor, **14.16**
- Rotary well drilling, **6.138**
- Roughing type sand water filters, **3.16**
- Runoff curve number, **6.36**
- Ryzner stability index, **4.18**

- S-traps, **9.9**
- Sand filter:
 - air scouring, **3.17**
 - backwashing, **3.16**
- Sand interceptor, **3.30**
- Sanitary 3A standard, **1.9**
- Sanitary drainage, **9.7**
 - system design, **9.11**
- Sanitary effluent disposal methods, **9.20**
- Sanitary gravity sewers, **6.81**
- Sanitary sewer:
 - depth of burial, **6.96**
 - pipe material, **6.85**
 - quantity of sewage flow, **6.87**
 - separation, **6.98**
 - velocity, **6.96**
- Sanitary vent, **9.35**
 - sizing, **9.36**
- Saturated air, **14.6**
- Saturated steam, **11.2**
 - pressure, **11.3**
- Saturated zone, **6.3**
- Saturation temperature, **11.3**
- Scale, **4.16**
- Screen filter, **3.3**
- Screw type air compressor, **14.16**
- Screw type vacuum pump, **15.12**
- Scrim, **5.10**
- Scuppers for roofs, **9.43**
- Sea water:
 - equipment selection, **20.15**
 - filters, **20.12**
 - intake, **20.13**
 - organisms attachment, **20.11**
 - pipeline cleaning, **20.11**
 - piping materials, **20.14**
 - system, **20.11**
- Seconds Redwood viscosity, **12.2**
- Seconds Saybolt Fucol viscosity, **12.2**
- Seconds Saybolt Universal viscosity, **12.2**
- Seismic supports, **2.91**
- Semiconsolidated aquifer, **6.4**
- Semi-instantaneous type water heaters, **9.76**
- Semipermeable water filter membrane, **4.36**
- Sensible heat, **11.3**
- Separates of soil, **7.2**
- Septic system, **9.21**
 - absorption field, **9.19**
 - distribution boxes, **9.30**
 - mound systems, **9.32**
 - percolation tests, **9.26**
 - seepage beds, **9.29**
 - septic tank, **9.22**
 - serial distribution, **9.32**
 - soil absorption, **9., 9.27**
 - system, **9.19**
 - trenches, **9.29**
- Service deionization, **4.33**
- Service hot water, **9.76**
- Sewage ejectors, **9.16**
- Sewage lift pumps, **6.100**
 - discharge piping, **9.19**
- Sewage lift stations, **6.100**
- Sewage quantities, **9.33**
- Sewer cleaning and repair, **6.78**
- Sewer line clearance, **6.98**
- Sewer peak flow, **6.84**
- Sewer vacuum and pressure venting, **6.106**
- Shallow manhole, **6.82**
- Sidewall area, **9.44**
- Sieving, **3.3**
- Sight glass, **22.58**
- Silt, **7.2**

- density index, **4.13**
- Site storm water retention, **6.35**
- Sliding vane:
 - air compressors, **14.14**
 - vacuum pumps, **15.20**
- Sludge, **4.14**
- Snow melt, **9.49**
- Sodium, **4.7**
- Soil, **7.2**
- Soil and aggregate backfill classification, **6.67**
- Soil structure, **7.2**
- Source water, **3.2**
- Solvent system, **9.34**
- Special waste:
 - pipe material and joint selection, **10.3**
 - pipe sizing, **10.3**
 - system approval, **10.2**
- Specialty compressed gases for laboratories, **14.64**
- Specialty gas:
 - alarms, **14.79**
 - check valves, **14.77**
 - classification, **14.65**
 - filters, **14.75**
 - ceramic, **14.75**
 - fiberglass, **14.75**
 - housing, **14.75**
 - molecular sieve, **14.75**
 - sintered metal, **14.75**
 - flash arresters, **14.78**
 - flow limit valve, **14.77**
 - gauges, **14.76**
 - generators, **14.70**
 - mixers, **14.80**
 - pipe material selection, **14.80**
 - pipe sizing, **14.88**
 - relief valves, **14.76**
 - system tests, **14.96**
 - valves, **14.78**
- Specialty gas grades, **14.65**
- Specific conductance, **4.12**
- Specific resistance, **4.11**
- Specific volume, **11.7**
- Spray type display fountain nozzles, **18.2**
- Stainless steel:
 - finishes, **2.11**
 - jackets, **5.12**
- Standard air, **14.4**
- Standard atmosphere, **14.3**
- Standard atmospheric pressure, **14.3**
 - vacuum, **15.3**
- Standard atmospheric temperature, **14.3**
- Standard cubic feet per minute, **14.4**
- Static water pressure, **6.146**
- Steady state heat flow, **5.2**
- Steam, **11.2, 11.13**
 - boilers, **11.13**
 - collection legs, **11.36**
 - condensate, **11.33**
 - dryness fraction, **11.2**
 - from a facility, **11.14**
 - generators:
 - clean steam, **11.14**
 - electric, **11.14**
 - heat tracing, **5.50**
 - condensate return, **5.62**
 - meters, **11.18**
 - nozzles, **11.28**
 - pipe sizing, **11.28**
 - pressure, **11.7**
 - reducing valve, **11.14**
 - quality, **11.2**
 - saturation point, **11.2**
 - separators, **11.18**
 - supply systems, **11.9**
 - system:
 - classifications, **11.7**
 - venting, **11.8**
 - temperature, **11.2**
 - tracers, **11.28**
 - trap, **11.19**
 - discharge lines, **11.34**
 - diversity factor, **11.45**
 - load safety factor, **11.43**
 - selection, **11.39**
 - water hammer, **11.9**
- Stepped rotor air compressors, **14.13**
- Storage tank definitions, **12.1**
- Storage type water heaters, **9.77**
- Storm distribution, **6.36**
- Storm water:
 - discharge regulations, **6.108**
 - drainage, interior, **9.42**
 - drywells, **9.54**
 - recharge basins, **9.53**
 - retention, **6.35**
- Straight lobe air compressors, **14.16**
- Strain vacuum gauge, **15.17**
- Strainer, **3.7**
 - basket, **3.9**
 - bodies, **3.8**
 - “Y” type, **3.8**
- Straining, **3.3**

- Strength of pipe materials, **6.69**
- Stress-corrosion, **4.15**
- Subgrade drainage, **6.5**
- Submersible pumps, **9.16**
- Subsurface drainage, **6.5**
- Subsurface water, **6.2**
- Suds pressure areas, **9.14**
- Suds relief vents, **9.15**
- Sulfates, **4.6**
- Sump and ejector control, **9.18**
 - electrode type, **9.18**
 - float type, **9.18**
 - mercury switch, **9.18**
 - pneumatic type, **9.18**
- Sump and ejector pump:
 - receiver design, **9.19**
 - types:
 - cantilever type, **9.17**
 - submersible type, **9.16**
 - vertical lift type, **9.17**
- Sump and ejector vents, **9.40**
- Sump pumps, **9.15**
- Superheated steam, **11.6**
- Superimposed load, **6.57**
- Supervised heat-up, **11.42**
- Surface film factor, **5.20**
- Surface filter, **3.3**
- Surface storm water drainage, **6.10**
- Surgical/medical air compressor, **14.106**
 - air dryers, **14.107**
 - assembly, **14.106**
 - filters, **14.107**
 - intakes, **14.106**
 - receivers, **14.107**
- Surgical/medical gas:
 - alarms, **14.113**
 - anesthetizing locations, **14.112**
 - area alarms, **14.113**
 - flow rate and diversity factor, **14.122**
 - high gas pressure, **14.124**
 - manual branch shutoff valve, **14.113**
 - master alarm, **14.113**
 - station outlets, **14.117**
 - pressure gauges, **14.113**
 - riser valve, **14.112**
 - source shutoff valve, **14.111**
 - system and equipment sizing, **14.116**
 - system pipe sizing, **14.124**
 - system testing, **14.115**
 - valves and valve locations, **14.111**
- Surgical/medical low-pressure gas pressure losses, **14.122**
- Surgical/medical pipe materials, **14.110**
- Suspended solids, **4.12**
- Swine cooling systems, **16.19**
- Tank connections and access for USTs, **12.8**
- Tank tightness with inventory control for USTs, **12.23**
- Temperature, **5.2**
- Temperature measurements, **22.35**
 - bimetallic devices, **22.35**
 - change of state, **22.35**
 - infrared, **22.36**
 - resistive, **22.37**
 - silicon diode, **22.36**
 - thermocouples, **22.36**
- Temperature and pressure relief valves, **9.88**
- Terminal equipment temperature control, **11.26**
- Testing of the underground piping network, **12.45**
- Testing of the underground storage tank, **12.45**
- Thermal conductivity, **5.3, 5.40**
- Thermal resistance, **5.3**
- Thermal transmittance, **5.4**
- Thermodynamic steam trap, **11.25**
- Thermostatic mixing valves, **9.89**
- Thermostatic steam traps, **11.23**
- Thermowells, **22.58**
- Tightness testing, **12.45**
- Time in pipe, **6.29**
- Time of concentration, **6.28**
- Torr, **15.2**
- Total dissolved solids, **4.12**
- Total heat flow, **5.3**
- Total organic carbon, **4.13**
- Total thermal resistance, **5.3**
- Toxic and flammable gas monitors, **14.80**
- Transition width, **6.57**
- Transpiration, **7.3**
- Trap arm, **9.9**
- Traps, **9.9**
- Turbidity, **4.5**
- Turbine type water meter, **9.56**
- Two-phase flow, **8.10**
- Two-pipe steam distribution, **11.10**
- Ultrafiltration, **4.40**
- Ultrasonic decontamination, **10.19**
- Unconfined aquifers, **6.4**
- Unconsolidated aquifers, **6.4**
- Unconsolidated rock, **6.3**

- Underground liquid fuel piping installation, **12.50**
- Underground pressurized delivery system leakage, **12.22**
- Underground storage tank, **12.7**
 - bottom shield, **12.13**
 - clad steel, **12.7**
 - composite tank, **12.7**
 - electronic tank gauging, **12.18**
 - interstitial space, **12.8**
 - leak detection and system monitoring, **12.17**
 - manual tank gauging, **12.17**
 - mechanical tank gauging, **12.18**
 - overflow prevention, **12.14**
 - secondary containment tank, **12.8**
 - spill prevention, **12.13**
 - tank containment system evaluation, **12.47**
 - tank filling and spill prevention, **12.11**
 - tank manway, **12.8**
- Underground suction delivery system leakage, **12.23**
- Underwriters Laboratories, **1.8**
- Uniformly distributed load, **6.65**
- Unions, **2.33**
- Units of radiation dose, **10.14**
- Unrestricted radiation area, **10.15**
- Unsaturated zone, **6.3**
- Upfeed water supply systems, **9.60**
- USP purified water, **4.53**
- UST (*see* Underground storage tank)
- Utility compressed air, **14.33**
- Utility water treatment, **4.44**

- Vacuum, **15.1**
 - perfect, **14.3**
- Vacuum capture pump, **15.12**
- Vacuum cleaning system, **15.49**
 - air bleed control, **15.52**
 - check valve, **15.48**
 - control and check valves, **15.52**
 - exhauster:
 - discharge, **15.59**
 - rating adjustments, **15.61**
 - sizing, **15.61**
 - filters, **15.51**
 - hose flow rate, **15.51**
 - inlets, **15.54**
 - tool size, **15.55**
 - location and spacing, **15.54**
 - pipe and fittings, **15.53**
 - pipe sizing, **15.53**
 - recommended velocity, **15.56**
 - separator, **15.51**
 - sizing, **15.60**
 - silencers, **15.51**
 - simultaneous operators, **15.54**
 - vacuum pressure, **15.56**
 - valve and hose sizing, **15.55**
- Vacuum condensate return system, **11.12**
- Vacuum ejector pump, **15.13**
- Vacuum gas transfer pumps, **15.12**
- Vacuum leakage, **15.10**
- Vacuum level measurement, **15.1**
 - reference points, **15.1**
- Vacuum pressure gauges, **15.15**
- Vacuum pressures, **15.1**
- Vacuum pump seal liquids, **15.14**
- Vacuum system force, **15.9**
- Valence, **4.3**
- Valve, **2.54**
 - ball valve, **2.72**
 - butterfly valve, **2.73**
 - check valve, **2.74**
 - conduit valve, **2.77**
 - diaphragm valve, **2.73**
 - flow control valve, **2.77**
 - gate valve, **2.64**
 - globe valve, **2.67**
 - level control valve, **2.77**
 - pinch valve, **2.74**
 - plug valve, **2.69**
 - pressure control valve, **2.77**
 - pump control, **2.75**
- Valve actuators, **2.56**
 - electric actuators, **2.59**
 - hydraulic actuators, **2.60**
 - manual, **2.56**
 - pneumatic actuators, **2.59**
- Valve ratings, **2.62**
- Valve selection, **2.60**
- Vapor barrier, **5.4**
- Vapor density, **12.2**
- Vapor monitoring, **12.20**
- Vapor recovery:
 - phase I, **12.24**
 - coaxial recovery, **12.24**
 - two-point system, **12.24**
 - phase II, **12.25**
 - balanced vapor recovery system, **12.25**
 - vacuum vapor recovery system, **12.25**
- systems, **12.23**
- Vapor steam system, **11.10**

- Vaporizer, **8.8**
- Velocity of gas stream under vacuum, **15.9**
- Vent headers, **9.40**
- Vent system design, **9.36**
- Vent terminals, **9.37**
- Vertical lift pumps, **9.15**
- Viscosity, **12.2, 22.2**
- Void filter volume, **3.5**
- Volatile liquid interceptor, **3.28**
- Volatile organic hydrocarbons, **12.2**
- Volumetric latent heat of fusion, **5.38**

- Wafer butterfly valve, **2.73**
- WAGD (*see* Waste anesthetic gas disposal system)
 - high vacuum active, **15.34**
 - low vacuum active, **15.33**
 - passive, **15.33**
 - room air changes, **15.33**
 - sizing, **15.34**
- Waste anesthetic gas disposal system, **15.32**
- Washing for nuclear decontamination, **10.19**
- Water, air, and vacuum relief valve, **6.126**
- Water booster pump systems, **9.68**
- Water display:
 - fountain:
 - custom design, **18.1**
 - kit, **18.1**
 - self-contained, **18.1**
 - fountains and pools, **18.1**
 - reflecting pool, **18.1**
 - system, **18.3**
- Water fixture units, **9.3**
- Water for injection, **4.53**
- Water from surface water sources, **6.142**
- Water heater sizing, **9.79**
- Water heating methods and equipment, **9.76**
- Water impurity analysis, **4.9**
- Water main backflow prevention, **6.118**
- Water meters, **6.122**
- Water pressure:
 - adjustment, **9.64**
 - boosting systems, **9.73**
 - regulating valve selection, **9.65**
- Water softening, **4.34**
- Water supply distribution system, **9.62**
- Water table, **6.3**
- Water treatment, **4.1**
- Water vapor migration, **5.4**

- Water vapor transmission rate, **5.5**
- Watt-hour, **5.2**
- Wear plate, **12.13**
- Weight of water vapor, **14.8**
- Weld testing, **2.41**
- Welded joint types, **2.40**
- Welder qualification, **2.41**
- Welding, **2.40**
 - gas metal arc welding, **2.40**
 - gas tungsten arc welding, **2.40**
 - orbital welding, **2.42**
 - oxy-fuel torch welding, **2.42**
 - shielded metal arc welding, **2.41**
- Well casing, **6.134**
- Well design and construction, **6.138**
- Well development:
 - air lifting, **6.140**
 - air surging, **6.139**
 - high-velocity jetting, **6.140**
 - overpumping, **6.139**
 - rawhiding, **6.139**
 - surging, **6.139**
- Well development and testing, **6.139**
- Well drawdown, **6.141**
- Well drilling, **6.137**
- Well grouting, **6.137**
- Well intakes, **6.136**
- Well points, **6.6**
- Well pumps, **6.131**
- Well screen, **6.136**
- Well testing for yield, **6.140**
- Well water:
 - level measurement, **6.140**
 - pumps, **6.131**
 - yield, **6.140**
- Wells, **6.131**
- Wet steam, **11.3**
- Wet vacuum cleaning system, **15.49**
- Wet vents, **9.39**
- Wet wells, **6.101**
- Wetted surface area of tanks, **13.33**
- Wire mesh jacket, **5.12**
- Wound filter, **3.20**

- X-rays, **10.8**

- Y strainer, **3.8**

- Zero governor fuel gas regulator, **13.7**
- Zone of aeration, **6.3**